

Technical Compliance Statement



Ref. No.: ACWE-RC200229 (ACWE-C1W2009053)

For the following equipment

Applicant : JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD.
Manufacturer : JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD.
Product : Grid-Tied PV Inverter
Model Number : (1)GW250K-HT (2)GW225K-HT
Brand : GOODWE

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards and found in compliance with the council EMC directive 2014/30/EU. The test data & results are issued on the EMC test report No. **ACWE-E2011024**.

Emission: EN 61000-6-4:2007+A1:2011 (IEC 61000-6-4:2006+A1:2010)
and AS/NZS 61000.6.4: 2012
EN 61000-3-11:2000, EN 61000-3-12:2011+AC:2013
(IEC 61000-3-11:2000, IEC 61000-3-12:2011)

Immunity: EN 61000-6-2:2005 (IEC 61000-6-2:2016)
(IEC 61000-4-2:2008, IEC 61000-4-3:2006+A2:2010,
IEC 61000-4-4:2012, IEC 61000-4-5:2014,
IEC 61000-4-6:2013, IEC 61000-4-8:2009, IEC 61000-4-11:2004)

Dec.01, 2020

Ken Lu/ Vice General Manager

AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.

The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.